

**The Security Printing Corporation (Bangladesh) Ltd,
Gazipur.**

Minutes of Pre-bid meeting regarding tender of Turn key project for supply, installation, testing and commissioning of Addressable Alarm Control Panel System along with Smoke, Heat & Multi Detector against tender no. 32/2017-2018 to be opened on 28.11.17.

A pre-bid meeting for the captioned system was held on the 15th November, 2017 as specified in the concerned tender schedule at the Board Room of the SPCBL. Sk Azizul Haque Managing Director of the SPCBL presided over the meeting. The other representatives of the SPCBL who attended the meeting are as follows :

1. Mr. Md Azharul Islam, G.M (BNP),SPCBL
2. Mr. Mahabubar Rahman, Chief Engineer, SPCBL.
3. Mr. Md. Anwar Hossain Chowdhury,GM(OSP) SPCBL.
4. Mr MD. Ehteshamul Karim ,G.M.(F&A),SPCBL.
5. Mr. Lt. Col. (rtd) Humayun Kabir,G.M (Security),SPCBL.
6. Mr. Md. Syed Amjad Hossain, DGM, SPCBL.
7. Mr. Md. Mojibor Rahman Akand, DGM (F.P)
8. Mr. Md. Enamul Haque Zoardar, DCE, SPCBL.
9. Mr. Md. Jobaidul Islam,Manager SPCBL.

On the otherhand the following representatives of the intending tenderers were present at the meeting:

1. Mr. Md. Towfiq Ahmed Khan, ATS Group.
2. Mr. Mohmad Mehedi Hasan, ATS Group.
3. Mr.Md. Zulmat Hasan, ATS Group.
4. Mr. S.K. Md. Shaheen,Ezzy Group.
5. Mr. Khalilur Rahman, Protechno.
6. Mr. Azad Zahirul Islam, Protechno.
7. Mr. Supan Roy, BTRL

The President welcomed the representatives of the intending Tenderers and invited them to raise any issue they feel to be explicated from SPCBL's end on the technical specification and the terms and conditions setforth in the concern e-tender schedule. The points raised by the different representatives and decision taken thereof are as follows:

Sl no	Clause & page of T.Schedule	Existing condition of the Tender Schedule	Amendment & addition at pre-bid meeting
1.	D-1 Page 5	<u>Addressable Fire Alarm Control Panel</u> Loops: Minimum 8 loops expandable upto 16 loops.	<u>Addressable Fire Alarm Control Panel</u> Loops: Minimum 8 loops expandable upto 10 loops.
2	D-2,3& 4 Page 5& 6		<u>Room height will be upto 25 feet.</u>
3	Notice B-5& C-15 page-x,1 & 15	Last date & time for submission of Offer/e-tender 28.11.17 upto 11 A.M	Last date & time for submission of Offer/e-tender <u>04.12.17</u> upto 11 A.M
4	B-6 & C-15 page-x,1 & 15	Date & time for opening of e-tender 28.11.17 at 11.15 A.M	Date & time for opening of e-tender <u>04.12.17</u> at 11.15 A.M

This minutes will be treated as an integral part of the tender schedule. Having no other issues for discussion the chair concludes the meeting with thanks to all.

(Sk. Azizul Haque)
Managing Director,SPCBL